

Supplement to the user information

„SILENTIO“ system control

Fill level measuring device and drinking water supply

Item no.: 351022

9. Special functions:

9.1 Pump out:

9.1.1 Description:

Your device has been fitted with an additional Pump out function. This enables water to be pumped out of the main tank. The switching point „pump out“ may be set as a menu point in the usual way.




Diagram 14: Plant layout example

9.2. Changes in the operation level:

The main menu level (see diagram 9) receives an additional menu point:




Diagram 15: main menu level

The menu point “Special functions” has the following contents:




Diagram 16: Menu point “Special functions”

Remark:

The chosen numeric value “PUMP OUT FROM” should always be greater than the numeric value for “VALVE CLOSED”.

The water will be pumped off when it rises above the set level. Pumping off begins when the water level is 2% below the set level, this function is to prevent a continuous switching on and off.